

# AENOR

## Certificate of conformity Plastics

001/006647

AENOR certifies that the organization

### HELIROMA PLASTICOS, S.A.

registered office ZONA INDUSTRIAL, EN-1 / IC-2, KM 250,5 3850-184  
ALBERGARIA-A-VELHA (Portugal)

supplies Polypropylene random with modified cristallinity pipes (PP-RCT) and  
glass fiber (PP-RCT)/PP-RCT+GF /PP-RCT) for installation of hot and cold  
water inside the building structure

in compliance with ESPECIFICACIÓN TÉCNICA AL RP 001.78

DESCRIPTION Trademark: ROMAFASER CT  
Fiberglass content: 6%  
Fiberglass content of the middle layer: 17%

See annex for more information.

Production site ZONA INDUSTRIAL, EN-1 / IC-2, KM 250,5 3850-184  
ALBERGARIA-A-VELHA (Portugal)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has  
verified the quality system implemented for its manufacture. AENOR  
performs these tasks periodically while the Certificate has not been  
cancelled, in accordance with Specific Rules RP 01.78.

This certificate supersedes 001/006647, dated 2018-09-18

First issued on 2016-11-07  
Modified on 2019-07-11  
Validity date 2021-11-07



Rafael GARCÍA MEIRO  
Chief Executive Officer

# AENOR

## Certificate of conformity Plastics

001/006647

### Annex to Certificate

DESCRIPTION Trademark: ROMAFASER CT  
Fiberglass content: 6%  
Fiberglass content of the middle layer: 17%

SERIE	DIAMETERS (mm)	APPLICATION CLASS / DESIGN PRESSURE (bar)	OPACITY
3,2	20 - 25 - 32	1/10 ; 2/10 ; 4/10 ; 5/8	Yes
5,0	40 - 50 - 63 - 75 - 90 - 110 - 125 - 160 - 200 - 250 - 315 - 355 - 400	1/6 ; 2/6 ; 4/6 ; 5/4	Yes

Original Electronic Certificate

First issued on 2016-11-07  
Modified on 2019-07-11  
Validity date 2021-11-07

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com